

ORIGINAL



0000163732

July 20, 2015

RECEIVED

2015 JUL 20 P 3:46

Arizona Corporation Commission
Docket Control
1200 W. Washington St.
Phoenix, AZ 85007

AZ CORP COMMISSION
DOCKET CONTROL

Subject: Links at Coyote Wash Utilities, LLC – Docket# SW04210A-10-0392
Compliance Item – Bi-annual Update on Odor Complaints & Actions taken

Since our last update on January 25, 2015, the operators & management of Links at Coyote Wash Utilities, LLC (LACW) received one formal odor complaints, and approximately three or four informal odor complaints. The most recent complaint was in April.

The complaints in April were due to a lift station failure which caused additional detention time for wastewater in the collection system and lift station. The equipment has been fixed and lift stations are operating normally at the present time.

In addition to the ongoing upgrades/ expansion of the WWTP this year, LACW is working with the town of Wellton on an automatic dosing system for fresh water to be periodically added into the WWTP distribution system. This will prevent sewage from sitting in the collection system at the more remote parts of the subdivision, for an inordinate amount of time, reducing odors when the sewage arrives at the WWTP. The system was installed in April and May and appears to be working well. The Town is benefitting from the system as it prevents their freshwater from sitting in their distribution system for too long, causing TTHM to build up to excessive levels.

Finally, we have increased the amount of time that the plant is being maintained by providing daily visits from our onsite maintenance staff, who perform the routine maintenance and cleaning of the WWTP, and conduct more regular testing. Wendy Cor Commission has been hired as our new Operator in Responsible Charge. She has nearly a decade of

DOCKETED


JUL 20 2015

DOCKETED BY	MLB
-------------	-----

experience working with sewer systems that involve long runs of collection system piping and remote lift stations (similar to Coyote Wash).

If you have any questions, please contact me.

Sincerely,

A handwritten signature in black ink, appearing to read 'Jason Williamson', with a stylized, cursive script.

Jason Williamson
Manager, Links at Coyote Wash Utilities, LLC
7581 E Academy Blvd. Suite 229
Denver, CO 80230
(720) 949-1384 x301